

April 20, 2021

WBCM
300 East Joppa Road, Suite 200
Baltimore MD, 21286
Attn: Keven Haley

RE: Merritt Point Park Boat Launch Replacement
Stormwater Management Variance
Baltimore Harbor Watershed
Project I.D. D921997
Tracking Number: 07-21-3443

Dear Mr. Haley;

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. Section 33-4-113 (a) (2) allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of the design standards would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the replacement of existing boat ramps by cut and cover. The existing cover conditions will be re-established once the new ramps are installed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff resulting from the project.

Please contact Ella Kaplan, E.I.T. at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Kritty Udhin, P.E., Manager
Stormwater Management
Department of Environmental Protection
& Sustainability

KU:eak